

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 3225-0751:104 Page 1 of 1

CATEGORY: Fire Dampers

LISTEE: Safe-Air, 1855 S. 54th, Cicero IL 60804
Contact: *Lee Stack (708) 652-9100

DESIGN: Models 471 and 472 fire dampers. Unit is constructed of No. 16 Ga. galvanized frame and blades, 1/2" hex. shape steel blade axles, and stainless steel jamb seal. Refer to listee's data sheet for additional detailed product description and operational considerations.

Min. Width	Max. Width	Min. Height	Max. Height
12"	24"	6"	24"

RATING: 1 hour

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, classification and UL label.

APPROVAL Listed as fire dampers for installation inside duct outlets in rated fire resistive assemblies. Intended for use with the following operators: 331-4826, M693-5095, MA-405, MA-318, MP-2659.

NOTE: For leakage rated dampers, please refer to CSFM Listing Category 3230.

*Rev. 06-11-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 11, 2002**

*Listing Expires **June 30, 2003***

Authorized By: **DIANE K. AREND**, Senior Deputy
Program Manager